

CERTIFICATE ENEC/FI 2017021



Our Ref. 285812-2

Product Terminal block

Rating and principal characteristics 0,5-2,5 mm², 450 V, T85

Trade mark (if any) 

Type PC225* series

Name and address of the licensee Heavy Power Co. Ltd.
No. 7, Lane 106, WuKung 3rd Road
New Taipei Industrial Park
NEW TAIPEI CITY 248, TAIWAN

Address of the manufacturer Heavy Power Co. Ltd.
No. 7, Lane 106, WuKung 3rd Road
New Taipei Industrial Park
NEW TAIPEI CITY 248, TAIWAN

Is in conformity with EN 60998-1:2004
EN 60998-2-2:2004

As shown in the Test Report(s) No(s) 285812-2

It is authorized to use of the marks ENEC 16 and FI

Validity This certificate is valid until 29 March 2022 provided that the Conditions for ENEC and FI certification are met. This certificate includes the right to use the ENEC 16 and FI mark under the condition that product changes (if any) will be approved at SGS Fimko before the product is brought onto market.


Directive information The certified product(s) fulfils requirements of above mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) at the date of issue of the certificate.

With the following limitations -

Date of issue 29 March 2017

SGS Fimko Ltd

Signature



Sixten Lökfors

Project Manager



This certificate has 2 pages



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Page No.: 2 of Certificate No.: ENEC/FI 2017021

Additional information



For rigid conductors 0,5-0,75-1-1,5-2,5 mm²

PC225* series:

PC2252	terminal block for two conductors
PC2253	terminal block for three conductors
PC2254	terminal block for four conductors
PC2255	terminal block for five conductors
PC2258	terminal block for eight conductors

This certificate replaces certificate ENEC/FI 2012019 dated 03 April 2012, due to new testing.

Manufacturing site(s)

Heavy Power Co., Ltd
Hsiao Tang Pao, Chu Shan
Dong Cheng, Dong Guan
CANTON 523120, CHINA