



Product Service

Attestation of Conformity

No. N8A 120531 0005 Rev. 00

Holder of Attestation: **JEONO CO., LTD.**

641 Aegibong-ro, Tongjin-eup
Gimpo-si, Gyeonggi-do 10010
REPUBLIC OF KOREA

Product: **Low voltage switchgear combination
(Terminal block)**

Model(s): **JOTN 150A, JOTN 200A**

Parameters:

Rated input voltage:	600V
Rated current:	200A (JOTN 200A), 150A (JOTN 150A)
Rated Cross-Section:	Max. 95 mm ² (JOTN 200A), Max. 50 mm ² (JOTN 150A)
Against ingress liquids:	IP20

Tested according to:

EN 60947-1:2007/A2:2014
EN 60947-7-1:2009

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: MAEB01203623

Date, 2023-12-05

(Harry Kwon)

Page 1 of 1

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



TUV®